



GOVERNMENT OF TAMIL NADU
DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

**(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated
23.09.2024 on the basis of affidavit by the applicant)**

Certificate Number : TN00126TVM44609

Issued Date : 24-07-2026

Organization Type : Educational Institutions

Expiry Date : 23-07-2027

**Name of the Organization : SHREE VEDHA VIDYALAYA SCHOOL
CBSE**

**Address : 245, Road Street, Arathivellore, R.K Puram Post, Cheyyar
Taluk, Tiruvannamalai District - 604407**

I, **Mr K BASKAR** owner/manager of the **SHREE VEDHA VIDYALAYA SCHOOL CBSE** functioning as **Educational Institutions** located at **Arathirivellur** in **Tiruvannamalai** district hereby declare that

- This Self-Declared Sanitation certificate is valid from **24-07-2026** to **23-07-2027** and will be renewed every year prior to the expiry of the current certificate with updated information.
 - Our premises can accommodate **185** people/pupils and has **40** urinals and **20** toilets which is proportionate to the number of users as per government norms.
 - **4** Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
 - The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
 - There is no potential mosquito breeding area on the premises.
 - The premises have adequate drinking water fountains on each floor of the premises.
 - The self-declared certificate is displayed prominently on the premises along with the protocol
- The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

Signature of the Owner/Manager



(அ) TN00126TVM44609 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.
(அல்லது)

(ஆ) கைப்பேசியில் பாரகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.
Genuineness of the certificate can be verified by.

(a) Keying in the unique certificate number TN00126TVM44609 in the URL

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.

**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY**

No. 1458, Kanchi Road, Vengikkal, Tiruvannamalai – 606604.

E-mail: tvmdistrictlab@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/067	Report Issue Date :	04.08.2025	Page No : 1 of 1
Invoice Details:	3644	ULR No : ----		

Client Name & Address : Shree Vedha Vidyalaya School,
Contact No / Email.ID : No.53,Arathrivellore,
Cheyyar Taluk-604407,
Thiruvannamalai.

Lab No		2025/067			
Sample Name	:	Water - Drinking Water			
Sample Description	:	Clear Colorless liquid			
Sample Source		RO Water			
Sample Submitted by	:	Customer – Baskar			
Location & Date	:	Arathri Velore & 01.08.2025			
Sample Container	:	Plastic – Good Condition			
Quantity of sample Received	:	2 Litre	Sample Condition on Receipt	:	Good
Sample Received On	:	01/08/2025	Environmental Condition Temp °C	:	23 – 27 °C
Test Commenced on	:	01/08/2025	Test Completed on	:	02/08/2025

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25°C	--	IS 3025: Part 11: 2022	7.38	6.5-8.5	No Relaxation
2	Total Hardness as CaCO ₃	mg/L	IS 3025: Part 21: 200 (RA:2023)	32	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	28	200	600
4	Chloride as Cl	mg/L	IS 3025: Part 32: 1988 (RA:2019)	13	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025: (Part 24/Sec 1): 2022 – Turbidity Method	8	200	400
6	Nitrate as NO ₃	mg/L	IS 3025: (Part 34/Sec-1): 2023 – Screening Method	0	45	No Relaxation
7	Fluoride as F	mg/L	IS 3025: (Part 60/Sec-1): 2023 - SPADNS Method;	0	1.0	1.5

Remark: The tested sample conformed to IS: 10500:2012 (RA: 2019) Drinking water Acceptable Limit / Permissible Limit specification with respect to above tested parameters.

---End of Report-----

Reviewed and Authorised by
K.Muthuraman - Executive Engineer

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue N / Date	01/03.01.2025	Amend. No / Date	00/-	Page No	1 of 1
----------------	---------------	------------------	------	---------	--------

**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY**

No. 1458, Kanchi Road, Vengikkal, Tiruvannamalai – 606604.

E-mail: tvmdistrictlab@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/067	Report Issue Date :	04.08.2025	Page No : 1 of 2
Invoice Details:	3644			

Client Name & Address : Shree Vedha Vidyalaya School,
Contact No / Email.ID : No 53 Arathri Vellore,
Cheyyar Taluk-604407,
Thiruvannamalai.

Sample / Lab No		2025/067			
Sample Name	:	Water - Drinking Water			
Sample Description	:	Clear Colorless liquid			
Sample Source		RO Water			
Sample Submitted by	:	Customer - Baskar			
Location & Date	:	Arathri Vellore & 01.08.2025			
Sample Container	:	Plastic – Good Condition			
Quantity of sample Received	:	2 Litre	Sample Condition on Receipt	:	Good
Sample Received On	:	01/08/2025	Environmental Condition Temp °C	:	23 – 27 °C
Test Commenced on	:	01/08/2025	Test Completed on	:	02/08/2025

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	--	Visual	Clear Colorless liquid	--	--
2	Odour	--	IS 3025: Part 5: 2018	Agreeable	--	--
3	Turbidity	NTU	IS 3025: Part 10: 2023	< 0.5	1	5
4	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	59	500	2000
5	EC @ 25°C	µS/cm	IS 3025: Part 14: 2013	84	--	--
6	P- Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	Nil	--	--
7	Calcium as Ca	mg/L	IS 3025: Part 40: 1991	4	75	200
8	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	0	30	100

Reviewed and Authorised by
K.Muthuraman - Executive Engineer

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue N / Date	01/03.01.2025	Amend .No / Date	00/-	Page No	1 of 2
----------------	---------------	------------------	------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 1458, Kanchi Road, Vengikkal, Tiruvannamalai – 606604.

E-mail: tvmdistrictlab@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/067	Report Issue Date :	04.08.2025	Page No : 2 of 2
Invoice Details:	3644			

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
9	Iron as Fe mg/L	mg/L	IS 3025 (Part 53) : 2024	< 0.1	0.3	No Relaxation
10	Manganese as Mn	mg/L	IS 3025 (Part 59) : 2023	< 0.05	0.1	0.3
11	Ammonia as NH ₃	mg/L	IS 3025 (Part 34) : 2023	< 0.1	0.5	No relaxation
12	Nitrite as NO ₂	mg/L	IS 3025 (Part 34/Sec-1) : 2023	< 0.005	--	--
13	Phosphate as PO ₄	mg/L	IS 3025 (Part 31/Sec-1) : 2022	< 0.1		
14	Oxygen Observed in 4 hrs.as O ₂ (Tidy's Test)	mg/L	IS 3025 (Part 63) : 2007	< 0.1	--	--
15	Residual Chlorine	mg/L	IS 3025 (Part 26) : 2007	< 0.2	0.2	1.0

Bacteriological Test

1	Total coliform	CFU / 100 ml	IS 15185 : 2016- RA : 2021	Absent	Absent/ 100 mL
2	Fecal coliform	CFU / 100 ml	IS 15185 : 2016- RA : 2021	Asbent	Absent / 100 mL

Remark: The tested sample conformed to IS: 10500:2012 (RA: 2019) Drinking water Acceptable Limit / Permissible Limit specification with respect to above tested parameters.

---End of Report-----


Reviewed and Authorised by
K.Muthuraman - Executive Engineer

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue N / Date	01/03.01.2025	Amend .No / Date	00/-	Page No	2 of 2
----------------	---------------	------------------	------	---------	--------